



NOTES:

- I. FOR 24" RCP & LARGER USE PIPE DIAMETER PLUS 12" FOR MINIMUM INSIDE DIMENSION.
- 2. 24" X 24" CASTING WITH 12",
 15" & 18" PIPE, 24" X 36"
 CASTING USED WITH 24" PIPE
 OR LARGER. IF PLACED WITHIN
 PUBLIC R/W CASTING MUST BE
 TRAFFIC BEARING TYPE PER
 NCDOT STANDARDS.
- 3. USE 4" X 4" X 8" OR 4" X 8" X
 16" SOLID CONCRETE BLOCK. CAST
 IN PLACE OR PRECAST CONCRETE TO
 MEET N.C.D.O.T. STANDARDS
 ACCEPTABLE.
- 4. FOR STEP REQUIREMENT; SEE NOTE 2 ON STANDARD NO. 30.01.

CIT	Υ	OF	RALEIGH
PUBLIC.	W	ORKS	DEPARTMENT

REVISIONS	DATE: 7/3/00	DRAWN BY:JTB	
5/20/04 JTT			
6/6/06 WDP	STANDARD		
	DROP	INLET	
	STD :	* 30.03	
	310.	. 10.01	

- DRAWING NOT TO SCALE -